

Project Name:	
Project Address:	Date:
Designer of Record:	Telephone:
Contact Person:	Telephone:
City:	

Mandatory Provisions Checklist

- Automatic lighting shutoff controls are provided based on either a scheduling device or an occupant sensor.
 - Exception: Space is intended for 24-hour operation.
 - Exception: Space is smaller than 5,000 ft².
- Each space enclosed by ceiling-height partitions has an independent, accessible control that operates general lighting in the space.
 - Exception: The control is located in a remote location for safety or security reasons.
- For spaces less than or equal to 10,000 ft², a separate space control is provided for each 2,500 ft² of area.
- For spaces more than 10,000 ft², a separate space control is provided for each 10,000 ft² of area.
- Either a photosensor or an astronomical time switch controls exterior lighting applications.
 - Exception: Lights must remain on for safety, security or eye adaptation reasons.
- Two-lamp tandem-wired ballasts.
- Display lighting has a separate control.
- Case lighting has a separate control.
- Hotel/motel guest rooms have a master switch at the main entry.
- Task lighting has a separate control.
- Nonvisual lighting has a separate control.
- Demonstration lighting has a separate control.
- Exit signs larger than 20 W have an efficacy greater than or equal to 35 lumens/W.
- Exterior luminaires greater than 100 W have lamps with minimum efficacy of 60 lumens/W.
 - Exception: Luminaire is activated with a motion sensor.

Interior Lighting Power Allowance (Building Area Method)

Building Type	Lighting Power Density (W/ft ²)	Building Area (ft ²)	Lighting Power Allowance (W)
Total			

Interior Lighting Power Allowance (Space-by-Space Method)

Building Type	Common/Specific Space Type	Lighting Power Density (W/ft ²)	Space Area (ft ²)	Lighting Power Allowance (W)
Total				



Project Name:	
Contact Person:	Telephone:

Additional Interior Connected Lighting Power

ID	Luminaire Description (including number of lamps per fixture, watts per lamp, type of ballast, type of fixture)	Type						Number of Luminaires	Watts/ Luminaire	Total Watts
		Incandescent	Fluorescent	HID	Line-Voltage Track	Low-Voltage Track	Other			
		<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>			
		<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>			
		<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>			
		<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>			
		<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>			
		<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>			
		<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>			
		<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>			
		<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>			
Total										

Exterior Building Lighting Power Allowance (except façades)

Application	Allowance	Area or Length (ft ² or ft)	Total Watts
Building entrance with canopy or free standing	3 W/ft ² of canopied area		
Building entrance without canopy	33 W/lin ft of door width		
Building exit	20 W/lin ft of door width		
Total			

Exterior Connected Lighting Power (except façades)

ID	Luminaire Description (including number of lamps per fixture, watts per lamp, type of ballast, type of fixture)	Number of Luminaires	Watts/ Luminaire	Total Watts
Total				

Building Façades Lighting Power Allowance

Application	Allowance	Area or Length (ft ² or ft)	Total Watts
Building façades	0.25 W/ft ² of illuminated façade area		

Building Façades Connected Lighting Power

ID	Luminaire Description (including number of lamps per fixture, watts per lamp, type of ballast, type of fixture)	Number of Luminaires	Watts/ Luminaire	Total Watts
Total				

